EnviroTest Laboratories Inc.

ANALYTICAL REPORT

Job Number: 420-110886-1

SDG Number: Monticello - Chase School

Job Description: Sullivan County BOCES

For:
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Attention: Jesse Morrill

Meredith Ruthven

Meredith W Ruthven
Customer Service Manager
mruthven@envirotestlaboratories.com
10/31/2016

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories Inc. certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative.

EnviroTest Laboratories, Inc. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOPH PH-0554

METHOD SUMMARY

Client: Sullivan County BOCES

Job Number: 420-110886-1
SDG Number: Monticello - Chase School

Description	Lab Location	Method	Preparation Method
Matrix: Water			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200

Lab References:

EnvTest = EnviroTest

Method References:

EPA = US Environmental Protection Agency

METHOD / ANALYST SUMMARY

Client: Sullivan County BOCES

Job Number: 420-110886-1
SDG Number: Monticello - Chase School

Method	Analyst	Analyst ID
EPA 200.8 Rev.5.4	Palentino, Gus J	GJP
EPA 200.8 Rev.5.4	Sirico, Derek	DS

SAMPLE SUMMARY

Client: Sullivan County BOCES

Job Number: 420-110886-1
SDG Number: Monticello - Chase School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-110886-1	NUR-S (NURSES OFFICE SINK)	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-2	NUR-BS (NURSES OFFICE BATH SINK)	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-3	112-BS (LIBRARY BATHROOM SINK)	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-4	113-BS (Classroom Sink)	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-5	221-S	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-6	219-S	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-7	217-S	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-8	215-S	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-9	207-S	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-10	204-S	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-11	114-S	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-12	114-BS	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-13	115-S	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-14	115-BS	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-15	116-S	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-16	116-BS	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-17	117-S	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-18	117-BS	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-19	123-S	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-20	123-BS	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-21	124-S	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-22	124-BS	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-23	125-S	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-24	125-BS	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-25	126-S	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-26	126-BS	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-27	102-S	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-28	106-BS	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-29	107-BS	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-30	119-BS	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-31	131-SL	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-32	KIT-BS	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-33	BRL-EW	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-34	120-S	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-35	117-S1 (RIGHT SIDE SINK)	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-36	208-BS	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-37	209-BS	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-38	212-S	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-39	HB-1	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-40	133-S	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-41	HB-2	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-42	HB-3	Drinking Water	09/27/2016 0600	09/27/2016 1442
420-110886-43	HB-4	Drinking Water	09/27/2016 0600	09/27/2016 1442

SAMPLE SUMMARY

Client: Sullivan County BOCES

Job Number: 420-110886-1
SDG Number: Monticello - Chase School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-110886-44	HB-5	Drinking Water	09/27/2016 0600	09/27/2016 1442

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **NUR-S (NURSES OFFICE SINK)**
Lab Sample ID: **420-110886-1**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/24/2016 1803	
Prep Method: 200		Date Prepared:		10/24/2016 0925	
Pb	1.91	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **NUR-BS (NURSES OFFICE BATH SINK)**
Lab Sample ID: **420-110886-2**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 1545	
Prep Method: 200		Date Prepared:		10/24/2016 1530	
Pb	2.17	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **112-BS (LIBRARY BATHROOM SINK)**
Lab Sample ID: **420-110886-3**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/24/2016 1805	
Prep Method: 200		Date Prepared:		10/24/2016 0925	
Pb	2.04	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **113-BS (Classroom Sink)**
Lab Sample ID: **420-110886-4**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/24/2016 1806	
Prep Method: 200		Date Prepared:		10/24/2016 0925	
Pb	2.72	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **221-S**
Lab Sample ID: **420-110886-5**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/24/2016 1807	
Prep Method: 200		Date Prepared:		10/24/2016 0925	
Pb	1.44	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **219-S**
Lab Sample ID: **420-110886-6**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/24/2016 1808	
Prep Method: 200			Date Prepared:		10/24/2016 0925	
Pb	1.00	U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **217-S**
Lab Sample ID: **420-110886-7**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/24/2016 1808	
Prep Method: 200		Date Prepared:		10/24/2016 0925	
Pb	1.13	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **215-S**
Lab Sample ID: **420-110886-8**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/24/2016 1809	
Prep Method: 200		Date Prepared:		10/24/2016 0925	
Pb	1.26	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **207-S**
Lab Sample ID: **420-110886-9**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/24/2016 1810	
Prep Method: 200			Date Prepared:		10/24/2016 0925	
Pb	1.00	U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **204-S**
Lab Sample ID: **420-110886-10**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/24/2016 1811	
Prep Method: 200		Date Prepared:		10/24/2016 0925	
Pb	1.28	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **114-S**
Lab Sample ID: **420-110886-11**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/24/2016 1811	
Prep Method: 200		Date Prepared:		10/24/2016 0925	
Pb	4.75	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **114-BS**
Lab Sample ID: **420-110886-12**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/24/2016 1812	
Prep Method: 200		Date Prepared:		10/24/2016 0925	
Pb	2.71	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **115-S**
Lab Sample ID: **420-110886-13**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/24/2016 1814	
Prep Method: 200		Date Prepared:		10/24/2016 0925	
Pb	5.79	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **115-BS**
Lab Sample ID: **420-110886-14**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/24/2016 1815	
Prep Method: 200		Date Prepared:		10/24/2016 0925	
Pb	4.79	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **116-S**
Lab Sample ID: **420-110886-15**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/24/2016 1816	
Prep Method: 200		Date Prepared:		10/24/2016 0925	
Pb	9.05	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **116-BS**
Lab Sample ID: **420-110886-16**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/24/2016 1817	
Prep Method: 200		Date Prepared:		10/24/2016 0925	
Pb	4.90	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **117-S**
Lab Sample ID: **420-110886-17**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 1357	
Prep Method: 200		Date Prepared:		10/24/2016 0925	
Pb	7.16	ug/L	2.00	2.00	2.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **117-BS**
Lab Sample ID: **420-110886-18**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/24/2016 1821	
Prep Method: 200		Date Prepared:		10/24/2016 0925	
Pb	3.32	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **123-S**
Lab Sample ID: **420-110886-19**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/24/2016 1821	
Prep Method: 200		Date Prepared:		10/24/2016 0925	
Pb	1.35	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **123-BS**
Lab Sample ID: **420-110886-20**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/24/2016 1824	
Prep Method: 200		Date Prepared:		10/24/2016 0925	
Pb	3.00	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **124-S**
Lab Sample ID: **420-110886-21**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/24/2016 1825	
Prep Method: 200		Date Prepared:		10/24/2016 1030	
Pb	7.62	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **124-BS**
Lab Sample ID: **420-110886-22**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/24/2016 1825	
Prep Method: 200		Date Prepared:		10/24/2016 1030	
Pb	4.04	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **125-S**
Lab Sample ID: **420-110886-23**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/24/2016 1826	
Prep Method: 200			Date Prepared:		10/24/2016 1030	
Pb	1.00	U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **125-BS**
Lab Sample ID: **420-110886-24**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/24/2016 1827	
Prep Method: 200		Date Prepared:		10/24/2016 1030	
Pb	3.52	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **126-S**
Lab Sample ID: **420-110886-25**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/24/2016 1828	
Prep Method: 200		Date Prepared:		10/24/2016 1030	
Pb	13.0	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **126-BS**
Lab Sample ID: **420-110886-26**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/24/2016 1828	
Prep Method: 200		Date Prepared:		10/24/2016 1030	
Pb	1.09	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **102-S**
Lab Sample ID: **420-110886-27**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/24/2016 1829	
Prep Method: 200		Date Prepared:		10/24/2016 1030	
Pb	4.17	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **106-BS**
Lab Sample ID: **420-110886-28**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/24/2016 1830	
Prep Method: 200			Date Prepared:		10/24/2016 1030	
Pb	1.00	U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **107-BS**
Lab Sample ID: **420-110886-29**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/24/2016 1831	
Prep Method: 200		Date Prepared:		10/24/2016 1030	
Pb	1.29	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **119-BS**
Lab Sample ID: **420-110886-30**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/24/2016 1833	
Prep Method: 200			Date Prepared:		10/24/2016 1030	
Pb	1.00	U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **131-SL**
Lab Sample ID: **420-110886-31**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/24/2016 1834	
Prep Method: 200		Date Prepared:		10/24/2016 1030	
Pb	11.8	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **KIT-BS**
Lab Sample ID: **420-110886-32**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/24/2016 1835	
Prep Method: 200		Date Prepared:		10/24/2016 1030	
Pb	4.60	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **BRL-EW**
Lab Sample ID: **420-110886-33**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/24/2016 1835	
Prep Method: 200			Date Prepared:		10/24/2016 1030	
Pb	65.9	g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **120-S**
Lab Sample ID: **420-110886-34**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/24/2016 1836	
Prep Method: 200		Date Prepared:		10/24/2016 1030	
Pb	3.11	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **117-S1 (RIGHT SIDE SINK)**
Lab Sample ID: **420-110886-35**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/24/2016 1837	
Prep Method: 200		Date Prepared:		10/24/2016 1030	
Pb	2.06	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **208-BS**
Lab Sample ID: **420-110886-36**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/24/2016 1838	
Prep Method: 200		Date Prepared:		10/24/2016 1030	
Pb	1.80	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **209-BS**
Lab Sample ID: **420-110886-37**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/24/2016 1532	
Prep Method: 200			Date Prepared:		10/24/2016 1030	
Pb	1.00	U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **212-S**
Lab Sample ID: **420-110886-38**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/24/2016 1540	
Prep Method: 200		Date Prepared:		10/24/2016 1030	
Pb	1.17	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **HB-1**
Lab Sample ID: **420-110886-39**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/24/2016 1542	
Prep Method: 200			Date Prepared:		10/24/2016 1030	
Pb	1.00	U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **133-S**
Lab Sample ID: **420-110886-40**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/24/2016 1543	
Prep Method: 200		Date Prepared:		10/24/2016 1030	
Pb	6.01	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **HB-2**
Lab Sample ID: **420-110886-41**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/24/2016 1545	
Prep Method: 200		Date Prepared:		10/24/2016 1030	
Pb	1.11	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **HB-3**
Lab Sample ID: **420-110886-42**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/25/2016 1648	
Prep Method: 200			Date Prepared:		10/24/2016 1530	
Pb	2720	g	ug/L	100	100	100

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **HB-4**
Lab Sample ID: **420-110886-43**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/24/2016 1547	
Prep Method: 200		Date Prepared:		10/24/2016 1030	
Pb	2.05	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110886-1
Sdg Number: Monticello - Chase School

Client Sample ID: **HB-5**
Lab Sample ID: **420-110886-44**

Date Sampled: 09/27/2016 0600
Date Received: 09/27/2016 1442
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/24/2016 1553	
Prep Method: 200			Date Prepared:		10/24/2016 1030	
Pb	35.2	g	ug/L	1.00	1.00	1.0

DATA REPORTING QUALIFIERS

Client: Sullivan County BOCES

Job Number:

Sdg Number: Monticello - Chase School

Lab Section	Qualifier	Description
Metals		
	g	Result fails applicable NYS drinking water standards
	U	The analyte was analyzed for but not detected at or above the lowest stated limit.

Certification Information

Client: Sullivan County BOCES

Job Number:

Sdg Number: Monticello - Chase School

The following analytes are Not Part of the ELAP scope of accreditation:

Sulfur, Tungsten, Silicon, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide, Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Phenolphthalein Alkalinity, Solids (Fixed), Solids (Percent), Solids (Percent Moisture) , Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), Total Inorganic Carbon, Volatile Acids as Acetic Acid, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, Iron Bacteria, Salmonella, & Sulfur Reducing Bacteria.

The following analytes are Not Part of ELAP Potable Water scope of accreditation:

Cobalt (200.7, 200.8), Tin (200.7), Strontium (200.7), Gold (200.7), Platinum (200.7), Palladium (200.7), Titanium (200.7), Phosphorus (365.3), Nitrate-Nitrite (10-107-4-1C, 353.2), m-Xylene & p-Xylene (502.2, 524), Naphthalene (502.2), o-Xylene (502.2, 524), & Fecal Coliform (9222D).

The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation:

Ammonia (SM 4500NH3G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

The following analytes are Not Part of ELAP Non Potable Water scope of accreditation:

Dissolved Organic Carbon (5310C), Mecoprop (8151A), & MCPA (8151A).

Definitions and Glossary

Client: Sullivan County BOCES

Job Number:

Sdg Number: Monticello - Chase School

Abbreviation	These commonly used abbreviations may or may not be present in this report.
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points.

MONTICELLO- CHASE SCHOOL

water samples 9/27/16

110886

	Sample #	Date	Time	AREA	250 ml HNO3	Analysis Requested
1	NUR-S	9/27/16	6AM	NURSES OFFICE SINK		LEAD
2	NUR-BS			NURSES OFFICE BATH SINK		
3	112-BS			LIBRARY BATHROOM SINK		
4	113-BS			Classroom sink		
5	221-S					
6	219-S					
7	217-S					
8	215-S					
9	207-S					
10	204-S					
11	114-S					
12	114-BS					
13	115-S					
14	115-BS					
15	116-S					
16	116-BS					
17	117-S					
18	117-BS					
19	123-S					
20	123-BS					
21	124-S					
22	124-BS					
23	125-S					
24	125-BS					
25	126-S					
26	126-BS					
27	102-S					
28	106-BS					
29	107-BS					
30	119-BS					
31	131-SL					
32	KIT-BS					
33	BRL-EW					
34	120-S					
35	117-S1			RIGHT SIDE SINK		
36	208-BS					
37	209-BS					
38	212-S					
39	HB-1					
40	133-S					
41	HB-2					
42	HB-3					
43	HB-4					
44	HB-5					

Sampled By: [signature] 9/27/16 0600

Relinquished By: [signature] ~~ETL~~ 9/27/16 1442 AE 9/27/16 Sullivan BOCES

Received By: A Elmendorf ETL 9/27/16 1442 IR #3, 25.2°C, no ice

LOGIN SAMPLE RECEIPT CHECK LIST

Client: Sullivan County BOCES

Job Number: 420-110886-1
SDG Number: Monticello - Chase School

Login Number: **110886**

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	
Cooler Temperature is recorded.	True	25.2 C
Cooler Temp. is within method specified range.(0-6 C PW, 0-8 C NPW, or BAC <10 C	False	
If false, was sample received on ice within 6 hours of collection.	False	
Based on above criteria cooler temperature is acceptable.	True	Method does not require cooling. AE 9/27/16
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	NA	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	