

ANALYTICAL REPORT

Job Number: 420-110682-1

SDG Number: Monticello C.S.

Job Description: Sullivan County BOCES

For:

Sullivan County BOCES

6 Weirk Avenue

Liberty, NY 12754

Attention: Jesse Morrill



Meredith W Ruthven

Customer Service Manager

mruthven@envirotestlaboratories.com

10/11/2016

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories Inc. certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative.

EnviroTest Laboratories, Inc. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOH PH-0554

METHOD SUMMARY

Client: Sullivan County BOCES

Job Number: 420-110682-1
SDG Number: Monticello C.S.

Description	Lab Location	Method	Preparation Method
Matrix: Water			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200

Lab References:

EnvTest = EnviroTest

Method References:

EPA = US Environmental Protection Agency

METHOD / ANALYST SUMMARY

Client: Sullivan County BOCES

Job Number: 420-110682-1
SDG Number: Monticello C.S.

Method	Analyst	Analyst ID
EPA 200.8 Rev.5.4	Sirico, Derek	DS

SAMPLE SUMMARY

Client: Sullivan County BOCES

Job Number: 420-110682-1
SDG Number: Monticello C.S.

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-110682-1	201-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-2	201-BS	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-3	203-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-4	203-BS	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-5	205-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-6	205-BS	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-7	207-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-8	207-BS	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-9	209-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-10	209-BS	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-11	211-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-12	213-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-13	215-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-14	217-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-15	217-BS	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-16	200-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-17	200-BS	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-18	202-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-19	202-BS	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-20	204-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-21	204-BS	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-22	206-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-23	206-BS	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-24	208-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-25	208-BS	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-26	210-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-27	210-BS	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-28	322-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-29	324-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-30	326-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-31	320-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-32	318-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-33	318-BS	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-34	314-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-35	312-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-36	312-BS	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-37	308-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-38	306-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-39	304-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-40	NUR-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-41	NUR-BS	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-42	BLR-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-43	GLR-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-44	108-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-45	108-BS	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-46	106-S	Drinking Water	09/22/2016 0730	09/22/2016 1433

SAMPLE SUMMARY

Client: Sullivan County BOCES

Job Number: 420-110682-1

SDG Number: Monticello C.S.

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-110682-47	106-BS	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-48	104-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-49	104-BS	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-50	102-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-51	102-BS	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-52	100-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-53	100-BS	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-54	101-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-55	101-BS	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-56	103-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-57	103-BS	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-58	105-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-59	105-BS	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-60	107-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-61	107-BS	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-62	109-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-63	109-BS	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-64	111-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-65	111-BS	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-66	113-BS	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-67	MN-WB1	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-68	MN-WB2	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-69	MN-MB1	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-70	MN-SL	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-71	217-S2	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-72	217-BS2	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-73	LIB-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-74	LIBBS	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-75	200B-S	Drinking Water	09/22/2016 0730	09/22/2016 1433
420-110682-76	200G-S	Drinking Water	09/22/2016 0730	09/22/2016 1433

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 201-S
Lab Sample ID: 420-110682-1

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/10/2016 0537		
Prep Method: 200			Date Prepared: 10/08/2016 1115		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 201-BS
Lab Sample ID: 420-110682-2

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/10/2016 0541	
Prep Method: 200			Date Prepared:	10/08/2016 1115	
Pb	4.36	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 203-S
Lab Sample ID: 420-110682-3

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/10/2016 0545		
Prep Method: 200			Date Prepared: 10/08/2016 1115		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 203-BS
Lab Sample ID: 420-110682-4

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/10/2016 0548		
Prep Method: 200			Date Prepared: 10/08/2016 1115		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 205-S
Lab Sample ID: 420-110682-5

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/10/2016 0552		
Prep Method: 200			Date Prepared: 10/08/2016 1115		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 205-BS
Lab Sample ID: 420-110682-6

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/10/2016 0555	
Prep Method: 200			Date Prepared:	10/08/2016 1115	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 207-S
Lab Sample ID: 420-110682-7

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/10/2016 0559	
Prep Method: 200			Date Prepared:	10/08/2016 1115	
Pb	2.83	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 207-BS
Lab Sample ID: 420-110682-8

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/10/2016 0610		
Prep Method: 200			Date Prepared: 10/08/2016 1115		
Pb	29.2 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 209-S
Lab Sample ID: 420-110682-9

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/10/2016 0613		
Prep Method: 200			Date Prepared: 10/08/2016 1115		
Pb	3.72	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 209-BS
Lab Sample ID: 420-110682-10

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/10/2016 0617	
Prep Method: 200			Date Prepared:	10/08/2016 1115	
Pb	5.59	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 211-S
Lab Sample ID: 420-110682-11

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/10/2016 0621		
Prep Method: 200			Date Prepared: 10/08/2016 1115		
Pb	7.23	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 213-S
Lab Sample ID: 420-110682-12

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/10/2016 0624	
Prep Method: 200			Date Prepared:	10/08/2016 1115	
Pb	3.84	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 215-S
Lab Sample ID: 420-110682-13

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/10/2016 0628	
Prep Method: 200			Date Prepared:	10/08/2016 1115	
Pb	7.19	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 217-S
Lab Sample ID: 420-110682-14

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/10/2016 0631	
Prep Method: 200			Date Prepared:	10/09/2016 0900	
Pb	2.80	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 217-BS
Lab Sample ID: 420-110682-15

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/10/2016 0653	
Prep Method: 200			Date Prepared:	10/09/2016 0900	
Pb	79.9 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 200-S
Lab Sample ID: 420-110682-16

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/10/2016 0657		
Prep Method: 200			Date Prepared: 10/09/2016 0900		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 200-BS
Lab Sample ID: 420-110682-17

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/10/2016 0700	
Prep Method: 200			Date Prepared:	10/09/2016 0900	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 202-S
Lab Sample ID: 420-110682-18

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/10/2016 0704	
Prep Method: 200			Date Prepared:	10/09/2016 0900	
Pb	1.37	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 202-BS
Lab Sample ID: 420-110682-19

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/10/2016 0707	
Prep Method: 200			Date Prepared:	10/09/2016 0900	
Pb	1.98	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 204-S
Lab Sample ID: 420-110682-20

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/10/2016 0711		
Prep Method: 200			Date Prepared: 10/09/2016 0900		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 204-BS
Lab Sample ID: 420-110682-21

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/10/2016 0715	
Prep Method: 200			Date Prepared:	10/09/2016 0900	
Pb	7.12	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 206-S
Lab Sample ID: 420-110682-22

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/10/2016 0718		
Prep Method: 200			Date Prepared: 10/09/2016 0900		
Pb	4.51	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 206-BS
Lab Sample ID: 420-110682-23

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/10/2016 0722		
Prep Method: 200			Date Prepared: 10/09/2016 0900		
Pb	15.2 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 208-S
Lab Sample ID: 420-110682-24

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/10/2016 0725	
Prep Method: 200			Date Prepared:	10/09/2016 0900	
Pb	3.63	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 208-BS
Lab Sample ID: 420-110682-25

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/10/2016 0736		
Prep Method: 200			Date Prepared: 10/09/2016 0900		
Pb	1.85	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 210-S
Lab Sample ID: 420-110682-26

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/10/2016 0740	
Prep Method: 200			Date Prepared:	10/09/2016 0900	
Pb	2.64	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 210-BS
Lab Sample ID: 420-110682-27

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/10/2016 0743	
Prep Method: 200			Date Prepared:	10/09/2016 0900	
Pb	7.94	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 322-S
Lab Sample ID: 420-110682-28

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/10/2016 0747		
Prep Method: 200			Date Prepared: 10/09/2016 0900		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 324-S
Lab Sample ID: 420-110682-29

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/10/2016 0751		
Prep Method: 200			Date Prepared: 10/09/2016 0900		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 326-S
Lab Sample ID: 420-110682-30

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/10/2016 0754		
Prep Method: 200			Date Prepared: 10/09/2016 0900		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 320-S
Lab Sample ID: 420-110682-31

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/10/2016 0758		
Prep Method: 200			Date Prepared: 10/09/2016 0900		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 318-S
Lab Sample ID: 420-110682-32

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/10/2016 0801		
Prep Method: 200			Date Prepared: 10/09/2016 0900		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 318-BS
Lab Sample ID: 420-110682-33

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/10/2016 0805		
Prep Method: 200			Date Prepared: 10/09/2016 0900		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 314-S
Lab Sample ID: 420-110682-34

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/10/2016 2335	
Prep Method: 200			Date Prepared:	10/09/2016 0900	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 312-S
Lab Sample ID: 420-110682-35

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/10/2016 2356		
Prep Method: 200			Date Prepared: 10/09/2016 0900		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 312-BS
Lab Sample ID: 420-110682-36

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/11/2016 0000	
Prep Method: 200			Date Prepared:	10/09/2016 0900	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 308-S
Lab Sample ID: 420-110682-37

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/11/2016 0003		
Prep Method: 200			Date Prepared: 10/09/2016 0900		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 306-S
Lab Sample ID: 420-110682-38

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/11/2016 0007	
Prep Method: 200			Date Prepared:	10/09/2016 0900	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 304-S
Lab Sample ID: 420-110682-39

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/11/2016 0010	
Prep Method: 200			Date Prepared:	10/09/2016 0900	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: NUR-S
Lab Sample ID: 420-110682-40

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/11/2016 0014		
Prep Method: 200			Date Prepared: 10/09/2016 0900		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: NUR-BS
Lab Sample ID: 420-110682-41

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				10/11/2016 0018	
Prep Method: 200				10/09/2016 0900	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: BLR-S
Lab Sample ID: 420-110682-42

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/11/2016 0028		
Prep Method: 200			Date Prepared: 10/09/2016 0900		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: GLR-S
Lab Sample ID: 420-110682-43

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/11/2016 0032	
Prep Method: 200			Date Prepared:	10/09/2016 0900	
Pb	6.13	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 108-S
Lab Sample ID: 420-110682-44

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/11/2016 0036	
Prep Method: 200			Date Prepared:	10/09/2016 0900	
Pb	4.58	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 108-BS
Lab Sample ID: 420-110682-45

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/11/2016 0039	
Prep Method: 200			Date Prepared:	10/09/2016 0900	
Pb	118 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 106-S
Lab Sample ID: 420-110682-46

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/11/2016 0043		
Prep Method: 200			Date Prepared: 10/09/2016 0900		
Pb	5.35	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 106-BS
Lab Sample ID: 420-110682-47

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/11/2016 0046	
Prep Method: 200			Date Prepared:	10/09/2016 0900	
Pb	41.9 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 104-S
Lab Sample ID: 420-110682-48

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/11/2016 0050	
Prep Method: 200			Date Prepared:	10/09/2016 0900	
Pb	2.41	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 104-BS
Lab Sample ID: 420-110682-49

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/11/2016 0053	
Prep Method: 200			Date Prepared:	10/09/2016 0900	
Pb	34.9 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 102-S
Lab Sample ID: 420-110682-50

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/11/2016 0057	
Prep Method: 200			Date Prepared:	10/09/2016 0900	
Pb	3.51	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 102-BS
Lab Sample ID: 420-110682-51

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/11/2016 0101	
Prep Method: 200			Date Prepared:	10/09/2016 0900	
Pb	26.7 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 100-S
Lab Sample ID: 420-110682-52

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/11/2016 0111		
Prep Method: 200			Date Prepared: 10/09/2016 0900		
Pb	3.01	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 100-BS
Lab Sample ID: 420-110682-53

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/11/2016 0115	
Prep Method: 200			Date Prepared:	10/09/2016 0900	
Pb	5.46	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 101-S
Lab Sample ID: 420-110682-54

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/11/2016 0118	
Prep Method: 200			Date Prepared:	10/09/2016 0900	
Pb	1.85	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 101-BS
Lab Sample ID: 420-110682-55

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/11/2016 0133	
Prep Method: 200			Date Prepared:	10/09/2016 0900	
Pb	3.31	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 103-S
Lab Sample ID: 420-110682-56

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/11/2016 0136		
Prep Method: 200			Date Prepared: 10/09/2016 0900		
Pb	16.2 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 103-BS
Lab Sample ID: 420-110682-57

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/11/2016 0140	
Prep Method: 200			Date Prepared:	10/09/2016 0900	
Pb	4.00	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 105-S
Lab Sample ID: 420-110682-58

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/11/2016 0143		
Prep Method: 200			Date Prepared: 10/09/2016 0900		
Pb	16.6 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 105-BS
Lab Sample ID: 420-110682-59

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/11/2016 0154		
Prep Method: 200			Date Prepared: 10/09/2016 0900		
Pb	1.75	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 107-S
Lab Sample ID: 420-110682-60

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/11/2016 0158	
Prep Method: 200			Date Prepared:	10/09/2016 0900	
Pb	3.76	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 107-BS
Lab Sample ID: 420-110682-61

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/11/2016 0201	
Prep Method: 200			Date Prepared:	10/09/2016 0900	
Pb	4.05	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 109-S
Lab Sample ID: 420-110682-62

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/11/2016 0205	
Prep Method: 200			Date Prepared:	10/09/2016 0900	
Pb	2.72	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 109-BS
Lab Sample ID: 420-110682-63

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/11/2016 0208	
Prep Method: 200			Date Prepared:	10/09/2016 0900	
Pb	33.3 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 111-S
Lab Sample ID: 420-110682-64

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/11/2016 0212		
Prep Method: 200			Date Prepared: 10/09/2016 0900		
Pb	2.47	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 111-BS
Lab Sample ID: 420-110682-65

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/11/2016 0216		
Prep Method: 200			Date Prepared: 10/09/2016 0900		
Pb	2.86	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 113-BS
Lab Sample ID: 420-110682-66

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/11/2016 0219	
Prep Method: 200			Date Prepared:	10/09/2016 0900	
Pb	3.59	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: MN-WB1
Lab Sample ID: 420-110682-67

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed: 10/11/2016 0223	
Prep Method: 200				Date Prepared: 10/09/2016 0900	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: MN-WB2
Lab Sample ID: 420-110682-68

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/11/2016 0226		
Prep Method: 200			Date Prepared: 10/09/2016 0900		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: MN-MB1
Lab Sample ID: 420-110682-69

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/11/2016 0237		
Prep Method: 200			Date Prepared: 10/09/2016 0900		
Pb	2.33	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: MN-SL
Lab Sample ID: 420-110682-70

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/11/2016 0241		
Prep Method: 200			Date Prepared: 10/09/2016 0900		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 217-S2
Lab Sample ID: 420-110682-71

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/11/2016 0244	
Prep Method: 200			Date Prepared:	10/09/2016 0900	
Pb	4.69	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 217-BS2
Lab Sample ID: 420-110682-72

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/11/2016 0248	
Prep Method: 200			Date Prepared:	10/09/2016 0900	
Pb	22.7 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: LIB-S
Lab Sample ID: 420-110682-73

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/11/2016 0251		
Prep Method: 200			Date Prepared: 10/09/2016 0900		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: LIBBS
Lab Sample ID: 420-110682-74

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/11/2016 0255		
Prep Method: 200			Date Prepared: 10/09/2016 1100		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 200B-S
Lab Sample ID: 420-110682-75

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/11/2016 0309		
Prep Method: 200			Date Prepared: 10/09/2016 1100		
Pb	5.16	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110682-1
Sdg Number: Monticello C.S.

Client Sample ID: 200G-S
Lab Sample ID: 420-110682-76

Date Sampled: 09/22/2016 0730
Date Received: 09/22/2016 1433
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/11/2016 0320		
Prep Method: 200			Date Prepared: 10/09/2016 1100		
Pb	1.03	ug/L	1.00	1.00	1.0

DATA REPORTING QUALIFIERS

Client: Sullivan County BOCES

Job Number:
Sdg Number: Monticello C.S.

Lab Section	Qualifier	Description
Metals	g	Result fails applicable NYS drinking water standards
	U	The analyte was analyzed for but not detected at or above the lowest stated limit.

Certification Information

Client: Sullivan County BOCES

Job Number:

Sdg Number: Monticello C.S.

The following analytes are Not Part of the ELAP scope of accreditation:

Sulfur, Tungsten, Silicon, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide, Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Phenolphthalien Alkalinity, Solids (Fixed), Solids (Percent), Solids (Percent Moisture) , Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), Total Inorganic Carbon, Volatile Acids as Acetic Acid, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, Iron Bacteria, Salmonella, & Sulfur Reducing Bacteria.

The following analytes are Not Part of ELAP Potable Water scope of accreditation:

Cobalt (200.7, 200.8), Tin (200.7), Strontium (200.7), Gold (200.7), Platinum (200.7), Palladium (200.7), Titanium (200.7), Phosphorus (365.3), Nitrate-Nitrite (10-107-4-1C, 353.2), m-Xylene & p-Xylene (502.2, 524), Naphthalene (502.2), o-Xylene (502.2, 524), & Fecal Coliform (9222D).

The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation:

Ammonia (SM 4500NH3G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

The following analytes are Not Part of ELAP Non Potable Water scope of accreditation:

Dissolved Organic Carbon (5310C), Mecoprop (8151A), & MCPA (8151A).

Definitions and Glossary

Client: Sullivan County BOCES

Job Number:

Sdg Number: Monticello C.S.

Abbreviation	These commonly used abbreviations may or may not be present in this report.
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points.

110682

CUSTOMER SCBOCES
ADDRESS 8 Wick Ave.
Liberty, NY 12734
CITY/STATE/ZIP Jesse Morrill (845) 295-4028
CONTACT PHONE
PROJECT LOCATION Monticello C.S.
PRJ NUMBER/P.O.#

REPORT TYPE
 STANDARD ISRA
 NJ REG
 NYASP A B
 OTHER

TURNAROUND
 NORMAL
 QUICK
 VERBAL

REPORT # (Lab Use Only)

NOTE: SAMPLE TEMPERATURE UPON RECEIPT MUST BE 4°C ± 2°C.

SAMPLE TEMP. 28.0 °C 12#3

SAMPLE REC'D. ON ICE Y N

pH CHECK Y N

CHLORINE RESIDUAL Y N

NY PUBLIC WATER SUPPLIES

SOURCE ID
ELRP TYPE
FEDERAL ID

ANALYSIS REQUESTED

MATRIX: DW=DRINKING WATER S=SOIL O=OIL WW=WASTE WATER
SL=SLUDGE GW=GROUND WATER

Sample #	DATE	TIME	SAMPLING	COMP (Y/N)	GRAB (Y/N)	MATRIX	Client I.D.
			40ml Glass HCL				
			Liter Glass HCL				
			250ml Amber H2SO4				
			Liter Amber Plain				
			250ml Plastic HNO3				
			250ml Plastic NaOH				
			Liter Plastic				
			Liter Plastic H2SO4				
			250ml Plastic Sterile				
			8oz Glass				
			2oz Glass				
			250ml Pl. NaOH/ZnAc				
			Total # of containers				

SAMPLES SUBMITTED FOR ANALYSIS WILL BE SUBJECT TO THE ENVIROTEST TERMS AND CONDITIONS OF SALE (SHORT FORM) UNLESS ALTERNATE TERMS ARE AGREED IN WRITING.

REQUISITED BY Jesse Morrill SCBOCES COMPANY
DATE 9/22/16 TIME 14:33

SAMPLED BY Jesse Morrill SCBOCES COMPANY
DATE 9/22/16 TIME 7:30

RECEIVED BY Jesse Morrill SCBOCES COMPANY
DATE 9/22/16 TIME 14:33

RECEIVED BY Jesse Morrill SCBOCES COMPANY
DATE 9/22/16 TIME 14:33

COMMENTS

110682

	Sample #	Date	Time	AREA	250 ml HNO3	Analysis Requested
1	201-S	9/22/16	7:30 Am	CLASSROOM SINK		LEAD
2	201-BS			CLASSROOM BATH SINK		
3	203-S					
4	203-BS					
5	205-S					
6	205-BS					
7	207-S					
8	207-BS					
9	209-S					
10	209-BS					
11	211-S					
12	213-S					
13	215-S					
14	217-S					
15	217-BS					
16	200-S					
17	200-BS					
18	202-S					
19	202-BS					
20	204-S					
21	204-BS					
22	206-S					
23	206-BS					
24	208-S					
25	208-BS					
26	210-S					
27	210-BS					
28	322-S					
29	324-S					
30	326-S					
31	320-S					
32	318-S					
33	318-BS					
34	314-S					
35	312-S					
36	312-BS					
	Sample #	Date	Time	AREA	250 ml HNO3	Analysis Requested
37	308-S					LEAD
38	306-S					
39	304-S					
40	NUR-S					
41	NUR-BS					
42	BLR-S					

Received by *DMoore* ETC 9/22/16 1433

Relinquished by: *[Signature]*

110682

43	GLR-S				
44	108-S				
45	108-BS				
46	106-S				
47	106-BS				
48	104-S				
49	104-BS				
50	102-S				
51	102-BS				
52	100-S				
53	100-BS				
54	101-S				
55	101-BS				
56	103-S				
57	103-BS				
58	105-S				
59	105-BS		OUTSIDE OF BATH		
60	107-S				
61	107-BS				
62	109-S				
63	109-BS				
64	111-S				
65	111-BS				
66	113-BS				
67	MN-WB1		MAIN HALL WOMENS BATH LEFT		
68	MN-WB2		MAIN HALL WOMENS BATH RIGHT		
69	MN-MB1		MAIN HALL MENS BATH SINK		
70	MN-SL		MAIN HALL CUSTODIAL SLOP SINK		
71	217-S2		LEFT SIDE SINK		
72	217-BS2		LEFT SIDE BATHROOM SINK		
73	LIB-S		LIBRARY SINK		
74	LIB-BS		LIBRARY BATHROOM SINK		
75	200B-S		200 WING BOYS ROOM SINK		
76	200G-S		200 WING GIRLS ROOM SINK		

Received by *R. Messer* 9/22/16 1433

Requested by!



LOGIN SAMPLE RECEIPT CHECK LIST

Client: Sullivan County BOCES

Job Number: 420-110682-1
SDG Number: Monticello C.S.

Login Number: 110682

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is recorded.	True	28.0 C
Cooler Temp. is within method specified range.(0-6 C PW, 0-8 C NPW, or BAC <10 C	False	
If false, was sample received on ice within 6 hours of collection.	True	
Based on above criteria cooler temperature is acceptable.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	Preserved with nitric acid at lab @ 9/22/16 1555. KM 9/22/16
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	NA	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	